



T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088
Travelers Rest, SC 29690

Model No.

B-0199-01-F12

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

This Space for Architect/Engineer Approval


Job Name _____ Date _____

Model Specified _____ Quantity _____


Customer/Wholesaler _____

Contractor _____

Architect/Engineer _____



55/64-27 UN
Female Thread



Product Specifications:
1.2 GPM Aerator, 55/64-27 UN Female Thread

Product Compliance:

ASME A12.18.1 / CSA B125.1
NSF 61 - Section 9
NSF 372 (Low Lead Content)